



ROOM ATMOSPHERE TEMPERATURE MIN 16 °C (59 °F) SETPOINT (18 to 24) °C ±2 °C (64 to 75) °F MAX 27 °C (81 °F) HUMIDITY ≤ 70% (non-cond.)

